Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. DWSD/2026-27/May-006 Dated: 14.05.2026

It is certified that an inspection team headed by ..Bajesh Kisku Prasad, Technical Manager
(Name of Officers with designation) from D.W.& S. Division (PHED), Hazaribagh
inspected the Sri Ram Krishna Sarda Math & Mission (Sri Ram Krishna Sarada Ashrama), Rabindra Path, Hazaribag - 825301
(Name & Address of the school) on 12.05.2026 (date of inspection) and on the basis of
Water Test Report (Attached) bearing no. 03 dated 14.05.2026
of District Level Water Testing Lab (PHED Lab) certified that
the Sri Ram Krishna Sarda Math & Mission, Hazaribag (Name of school) has safe drinking water
facilities for the students and members of staff of the institution. School is also maintains the
hygienic sanitation condition in the school building & the campus as per norms prescribed by the
Central/ State/ U.T. Govt.

This certificate is valid till 13.11.2026 (Six Months) only.

14/05/2026

Signature with Seal: .....
Name : .....
Designation : Quality Manager
Name & Address of the Office / Department: District Level Water Testing Laboratory D.W.&S. Division, Hazaribaagh

14/5/26

To
Sri Ramkrishna Math & Mission
Rabindra Path, Hazaribag -
(Name & Address of the Institution) 825301

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies.

Principal-Incharge
Sri Ramakrishna Sarada Ashrama
Vivekananda Central School
Rabindra Path, Hazaribag
Affiliation No. 3430121
School Code-66322

15/05/26,
Secretary
Sri Ramakrishna Sarada Ashrama
Rabindra Path, Hazaribag
Pin-825301, Jharkhand

District Level Water Testing Laboratory,Hazaribagh

Office of the Executive,Engineer,Drinking Water and Sanitation Division, Hazaribagh
-825301,Jharkhand,india.
Email: dlwtl.hazaribagh@gmail.com

Test Report

Report No:255		Date : 14.05.2026	
Issued To:	SRI RAMAKRISHNA SARDA MATH & MISSION (SRI RAMKRISHNA SARADA ASHRAM) RABINDRA PATH, , HAZARIBAG-825301	SAMPLE CODE:-03	
Sample Description / Type	G.W.	Sample Collected by	SUJEET KUMAR
Sample Location	FINAL OUTLET	Sample Quantity / Packing	2 L PVC Bottle
Date of Sampling	12.05.2026	Temperature	25±3°C
Date of start of Analysis	12.05.2026	Humidity	50±10 % RH
Date of Completion Analysis :	14.05.2026	Sampling Procedure	N/A
ULR No-	N\A		

Sl. No.	Parameter	Unit	Result	Method Reference	Specification as per BIS – 10500:2012 (Second Revision) Amendment – June 2015	
					Acceptable Limit	Permissible Limit (In Absence of Alternate source)
1	pH	-	7.21	APHA 23rd Edition 2017-4500-H^+ B, (Electrometric Method)	6.5 – 8.5	No relaxation
2	Turbidity	NTU	0.9	APHA-23rd Edition2017 -2130-A, (Nephelometric method)	1	5
3	Chloride (as Cl)	mg/L	20	APHA-23rd Edition 2017-4500- B, (Argentometric method)	250	1000
4	Total Hardness as $CaCO_3$	mg/L	310	APHA-23rd Edition 2017-2340-C (EDTA Titrimetric method)	200	600
5	Total Alkalinity as $CaCO_3$	mg/L	280	APHA-23rd Edition 2017-2320-B, (Titration Method)	200	600
6	Calcium as Ca+	mg/L	28.21	APHA-23rd Edition 2017-3500-Ca-B, (EDTA Titrimetric Method)	75	200
7	Magnesium as Mg+	mg/L	12.34	APHA-23rd Edition 2017-3500-Mg-B, (EDTA Titrimetric Method)	30	100
8	Fluoride as F	mg/L	0.36	APHA 23rd. Ed.2017-4500 F^- C, (Ion selective electrode method)	1.0	1.50
9	Colour	HU	1	APHA 23rd Edition (Visual Comparison Method)	5	15
10	Odour	—	Agreeable	IS 3025 (Part-5)	Agreeable	Agreeable
(B)	BACTERIOLOGICAL					
11	Total Coliform	CFU/100 mL	>1	APHA 23rd Ed. 2017-9222B (Membrane Filter Technique)	Shall not be detectable in any 100 mL Sample	
12	Thermotolerant(Fecal) Coliform/ E.Coli	CFU/100 mL	>1	APHA 23rd Ed. 2017-9222D (Membrane Filter Technique)	Shall not be detectable in any 100 mL Sample	

Remarks:-According to above parameters Water is fit for drinking Yes (✓) / No ( )

Specific contractual notes: -

- The results listed refer only to the tested sample and applicable parameter.
- This report shall not be reproduced except in full without approval of the laboratory.
- This report results apply to the sample as received.
- This report results relate only to the items tested.
- This report, in full or in part, shall not be used for advertising or as evidence in any court of law.
- Tested Sample shall be retained up to seven days from the date of issue of the test report
- The liability of the laboratory is limited to the invoiced amount.
- All disputes are subjected to the Hazaribagh Jurisdiction.
- NOTE:- BDL=Below Detection Limit

14/5/2026

Quality Manager
District Level Water Testing Laboratory
D W.&S Division. Hazaribaagh

Principal-Incharge
Ramakrishna Sarada Ashrama
Vivekananda Central School
Rabindra Path, Hazaribag

14/5/26

25/05/26

Secretary
Sri Ramakrishna Sarada Ashrama
Rabindra Path, Hazaribag